



**City of Junction City
Annual Drinking Water Quality Report
2004**

We're very pleased to provide you with this year's Annual Water Quality Report. We want to keep you informed about the water and services we have delivered to you over the past year. Our goal is and always has been, to provide to you a safe and dependable supply of drinking water.

Why am I receiving this report?

In 1996, Congress passed amendments to the Safe Water Drinking Act that require drinking water providers to give their customers important information about their water, including where it comes from, what is in the water, and how our water quality compares with federal standards.

What if I have questions about my water?

This report describes our water quality, and explains what the various laboratory test results mean to our customers. If you have any questions about this report or concerning your water utility, please contact Mike Leighton, City Administrator at 998-2153 (email: mleighton@ci.junction-city.or.us) or David Renshaw, Public Works Director at 998-2153 (email: drenshaw@ci.junction-city.or.us). We want our customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled City Council meetings. They are held on the second Tuesday of each month, at 6:30 p.m. at City Hall, 680 Greenwood, Junction City.

Where does our water come from?

Junction City, like many small cities, relies on groundwater for its domestic water supply. The City operates six wells that contribute to our drinking water supply. These wells draw from a deep aquifer. The well sites are:

<u>Well</u>	<u>Aquifer</u>	<u>Status</u>
13 th & Elm	deep	operational year round
5 th & Maple	deep	operational year round
3 rd & Cedar	deep	reserve-summer use only
8 th & Deal	deep	operational year round
8 th & Front	deep	off line 2004

We have a source water protection plan available for public review at City Hall, 680 Greenwood. The Drinking Water Protection Plan was developed in 1997, and provides information such as potential sources of contamination that could affect our water supply.

What contaminants might be in water?

The City of Junction City routinely monitors for contaminants in your drinking water according to Federal and State laws. There were no detected constituents for the monitoring period of January 1 to December 31, 2004. The City monitors some 75 different constituents in your drinking water, at an annual cost of approximately \$10,000; however due to additional testing requirements for 2004 the City spent \$22,206. Among other things, we test for:

- Organic compounds, including synthetic and volatile organic chemicals, are by-products of gas stations, urban storm water run-off and septic systems.
- Inorganic compounds, such as salts and metals occur naturally or are caused by urban storm run-off, mining or farming.
- Herbicides and pesticides can come from a variety of sources such as agriculture, storm water run-off and residential uses. PCB's (polychlorinated biphenyl) are chemical compounds that can be found in environmental pollution.
- Radioactive material occurs naturally or can result from oil and gas production and mining activities.

Trained City personnel check the chlorine residual levels at several locations throughout the distribution system 365 days a year. As an element of our Corrosion Control Program, weekly testing of phosphate, pH, and iron levels is also conducted. By conducting these tests we are able to determine the need to increase or decrease the level of chlorine or phosphate as necessary to maintain water quality. In addition, bacti samples are collected once a week and analyzed by an independent laboratory for Coliform bacteria and E.coli.

How can water become contaminated?

All sources of drinking water are subject to potential contamination by substances that are naturally or man made. These substances can be microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Definitions:

In the following tables you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level (AL) - the concentration of a contaminant, which, if exceeded, triggers treatment or other requirements, which a water system must follow.

Maximum Contaminant Level - (mandatory language) The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Non-Detects (ND) - laboratory analysis indicates that the constituent is not present.

Picocuries per liter (pCi/l) – a measure of radioactivity. One curie is the radioactivity of one gram of radium. There is a trillion (1,000,000,000,000) picocuries in one curie.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

2004 Water Test Results – Regulated Substances Detected

Microbiological Contaminants

<i>Contaminant</i>	<i>Violation Y/N</i>	<i>Level Detected</i>	<i>Unit of Measure</i>	<i>MCLG</i>	<i>MCL</i>	<i>Likely Source of Contamination</i>
Total Coliform Bacteria	N	Positive (2 of 76)	n/a	0	presence of Coliform bacteria in 5% of monthly samples	Naturally present in the environment

Radioactive Contaminants

<i>Contaminant</i>	<i>Violation Y/N</i>	<i>Level Detected</i>	<i>Unit of Measure</i>	<i>MCLG</i>	<i>MCL</i>	Likely Source of Contamination
Combined Radium (5 th & Maple Well)	N	1.77	pCi/l	1.01	5	Erosion of natural deposits

Disinfection By-Products Analysis

<i>Contaminant</i>	<i>Violation Y/N</i>	<i>Level Detected</i>	<i>Unit of Measure</i>	<i>MCLG</i>	<i>MCL</i>	Likely Source of Contamination
Haloacetic Acids (HAA5)	N	0.0176	mg/l	0.00150	0.06	By-products of disinfection process

Inorganic Contaminants

<i>Contaminant</i>	<i>Violation Y/N</i>	<i>Level Detected</i>	<i>Unit of Measure</i>	<i>MCLG</i>	<i>MCL</i>	Likely Source of Contamination
Arsenic	N	0.00111 (13 th & Elm) 0.00405 (8 th & Deal)	mg/l	n/a	0.05	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
Barium	N	0.0170 (13 th & Elm) 0.00828 (3 rd & Cedar) 0.0133 (5 th & Maple) 0.0297 (8 th & Deal)	mg/l	0.002	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Copper	N	100% of homes tested were less than the AL of 1.3	mg/l	1.3	AL = 90% of homes tested must have lead levels less than 1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Lead	N	98% of homes tested were less than the AL of 0.015	mg/l	0	AL = 90% of homes tested must have lead levels less than 0.015	Corrosion of household plumbing systems, erosion of natural deposits
Nitrate	N	0.18 (13 th & Elm)	mg/l	0.01	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits

Synthetic Organic Contaminants

Contaminant	Violation Y/N	Level Detected	Unit of Measure	MCLG	MCL	Likely Source of Contamination
Di(2-ethylhexyl)phthalate	N	0.00223 (8 th & Deal)	mg/l	0	0.00600	Discharge from rubber and chemical factories

The following substances were tested for but not detected in the city's drinking water:

Microbiological Contaminants

Fecal coliform and E.coli

Radioactive Contaminants

Gross Alpha

Combined Uranium

Disinfection By-Products (DPB)

Total Trihalomethanes (TTHM)

Inorganic Contaminants (IOC)

Antimony

Chromium

Nitrite (as Nitrogen)

Asbestos

Cyanide

Selenium

Beryllium

Fluoride

Thallium

Cadmium

Mercury

Synthetic Organic Contaminants including Pesticides and Herbicides - Regulated (SOC)

2,4-D

Dibromochloropropane

Methoxychlor

2,4,5-TP

Dinoseb

Pentachlorophenol

Di(2-ethylhexyl)adipate

Diquat

Picloram

Alachlor

Endothall

Polychlorinatedbiphenyls
(PCBs)

Atrazine

Ethylene Dibromide (EDB)

Simazine

Benzo(a)pyrene (PAH)

Glyphosate

Toxaphene

BHC-gamma (Lindane)

Heptachlor

Vydate

Carbofuran

Heptachlor epoxide

Chlordane

Hexachlorobenzene

Dalapon

Hexachlorocyclopentadiene

Synthetic Organic Contaminants including Pesticides and Herbicides - Unregulated (SOC)

3-Hydroxycarbofuran

Butachlor

Metolachlor

Aldicarb

Carbaryl

Metribuzin

Aldicarb sulfone

Dieldrin

Propachlor

Aldicarb Sulfoxide

Dicamba

1,2,3-Trichloropropane

Aldrin

Methomyl

Volatile Organic Contaminants - Regulated (VOC)

1,1-Dichloroethylene

Carbon tetrachloride

Styrene

1,1,1-Trichloroethane

Cis-1,2-Dichloroethylene

Tetrachloroethylene

1,1,2-Trichloroethane

Dichloromethane

Toluene

1,2-Dichloroethane

Ethylbenzene

Trans-1,2-Dichloroethylene

1,2-Dichloropropane

Monochlorobenzene

Trichloroethylene

1,2,4-Trichlorobenzene

o-Dichlorobenzene

Total Xylenes

Benzene

p-Dichlorobenzene

Vinyl chloride

Volatile Organic Contaminants - Unregulated (VOC)

1,1-Dichloroethane	Bromodichloromethane	p-Chlorotoluene
1,1-Dichloropropene	Bromoform	Dibromochloromethane
1,1,1,2-Tetrachloroethane	Bromomethane	Dibromomethane
1,1,2,2-Tetrachloroethane	Chloroethane	m-Dichlorobenzene
1,3-Dichloropropane	Chloroform	cis-1,3-Dichloropropene
2,2-Dichloropropane	Chloromethane	trans-1,3-Dichloropropene
Bromobenzene	o-Chlorotoluene	

What do these test results mean?

As you can see by the table, our system had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some constituents have been detected. The EPA has determined that your water IS SAFE at these levels.

What about people with special health problems?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Are there any plans to improve the water system?

As the City continues its programs to maintain a safe and dependable water supply it is necessary to make improvements in our water system. The costs of these improvements may be reflected in the rate structure. Recent maintenance efforts in this reporting period include planned improvements to upgrade the 8th & Front well so that it can be placed back in service as well as the continuation of replacing dilapidated 2" galvanized water lines.

Thank You! The City of Junction City works around the clock to provide top quality water to every tap. The water system is monitored seven days a week, 365 days per year. Our Utility Workers are required to achieve Water Distribution II certification through the Oregon Health Division. Should you experience any problems with your water or, just want to ask a question, please contact us. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.