



CURBED STREETS

NTS

NOTES:

1. 4' MIN. COVER REQUIRED ON SANITARY SEWER MAINS AND LATERALS.
2. LATERALS AND P/L CLEANOUTS TO BE INSTALLED DURING CONSTRUCTION OF SANITARY SEWER MAINS.
3. WATER TO BE INSTALLED 3' IN FRONT OF FACE OF CURB ON HIGH SIDE OF STREET. 36" MIN. COVER ON ALL WATERLINES.
4. STORM SEWER TO BE INSTALLED ON LOW SIDE OF STREET:
 - a) 2' FROM FACE OF CURB FOR <4' RIM TO INVERT
 - b) 6' FROM FACE OF CURB FOR >4' RIM TO INVERT (MH SYSTEM)
5. MAINTAIN MIN. 3' HORIZ. SEPARATION BETWEEN PUBLIC UTILITIES & PARALLEL PRIVATE UTILITIES. OTHER VERT. AND HORIZ. SEPARATION DISTANCES ARE CONTROLLED BY DEQ, OHD, AND OTHER PUBLIC/PRIVATE UTILITY COMPANIES.
6. UNITY TRENCH PER UTILITY COMPANY REQMTS. ON OPPOSITE SIDE OF STREET FROM WATER LINE.

LAST REVISION DATE:

COPYRIGHT 1998
WESTECH ENGINEERING, INC.

JANUARY 1998

TYP. UTILITY LOCATIONS (CURBED STREETS)

CITY:

JUNCTION CITY, OR

DRAWING NO.

101