



**SECTION A-A**

**NOTES:**

1. ALL PRECAST SECTIONS SHALL CONFORM TO THE REQUIREMENTS OF ASTM C-478.
2. DISTANCE FROM TOP OF OVERFLOW TO MH RIM SHALL BE BASED ON OVERFLOW CAPACITY CALC'S BY DESIGN ENGINEER. ASSUME ORIFICE CONTROL.
3. 60" MINIMUM DIA. MANHOLE REQUIRED FOR OUTLET PIPE LARGER THAN 15" OR INLET > 21".

LAST REVISION DATE: AUG 2007	
<b>POLLUTION/FLOW CONTROL MANHOLE W/OVERFLOW</b>	
(NTS)	
JUNCTION CITY, OR	DETAIL NO. <b>320</b>