



INSERT NOT TO PROTRUDE BEYOND INSIDE DIAMETER OF MAINLINE.

STAINLESS STEEL BAND 3 1/2" MIN. WIDTH.

6"

NOTES:

1. SERVICE SADDLES ALLOWED ON EXISTING SEWER MAINS ONLY. MANUFACTURED TEE-WYE FITTINGS SHALL BE USED ON ALL NEW MAINLINES.
2. THE TAP SHALL NOT BE MADE EXCEPT IN THE PRESENCE OF A CITY INSPECTOR; NOR SHALL ANY CONNECTION BE MADE WITHOUT CITY APPROVAL.
3. SERVICE SADDLES SHALL BE ROMAC STYLE "CB" OR EQUAL W/ VIRGIN SBR GASKET PER ASTM D2000 MBA 710.
4. HOLE IN MAIN SHALL BE CORE DRILLED.
5. ϕ OF TAP SHALL BE ABOVE SPRINGLINE.

LAST REVISION DATE: JANUARY 1998		<small> COPYRIGHT 1998 WESTECH ENGINEERING, INC. </small>
SERVICE SADDLE CONNECTION TO EXISTING SEWERS		
CITY: JUNCTION CITY, OR	DRAWING NO. 418	