



NOTE: PER ORS 92.044(7), VALVE BOXES MUST BE SET 1' MINIMUM CLEAR FROM ANY SURVEY MONUMENT

NOTES:

1. BACKFILL WITH GRANULAR BACKFILL.
2. ALLOWED ONLY ON PERMANENT DEAD END LINES IN CUL-DE-SACS WHICH CANNOT BE EXTENDED IN THE FUTURE.
3. ALL CONCRETE TO BE 3300 PSI @ 28 DAYS.
4. 2" BLOWOFF SIZE ASSUMES 40 PSI RESIDUAL PRESSURE.

LAST REVISION DATE: MAR 2008	COPYRIGHT 1996 WESTECH ENGINEERING, INC.
STANDARD BLOWOFF WITH PLUGGED END	
(NTS)	
JUNCTION CITY, OR	DETAIL NO. 507